

To.

P.K.R. Jain Sen. Sec. School,
Ambala City.

No.

3536

Dated: -

3/8/2022

Subject: - Building Safety Certificate PKR Jain Sr. Sec. Public School.


Reference: Your Application No.(P)27109/22 dated 12.07.2022.

The School building of P.K.R. Jain Sen. Sec. School, Ambala City has been inspected by the Sub Divisional Engineer, Provincial Sub Division No.7 alongwith JE concerned and as reported by him vide his letter No.1265 dated 26.07.2022 that building is inspected and visually it found safe for running School. The School building Safety Certificate is hereby given upto the period 2022-2023 with the following conditions:

1. Building of this School should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution will be responsible for safety of building from every angle and firefighting equipment should be in functional condition.
5. If the building of this school is to be extended, the same should be first approved from structural Engineer.
6. Proof checked structural drawings should be submitted to this office for record within 01 month after issuing the NOC.
7. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
8. NOC may be considered as cancelled by this office if the school violates any of the above points.

This is for your information.

DA/ Nil.



Executive Engineer,
Provincial Division No.1,
PWD (B&R), Ambala Cantt.

Endst.No.

Dated:

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.7, PWD B&R, Ambala Cantt for information w.r.t. his office Memo.No.1265 dated 26.07.2022.

DA/Nil.


Executive Engineer,
Provincial Division No.1,
PWD (B&R), Ambala Cantt.