

To

The Principal,  
P.K.R. Jain Sr. Sec. Public School,  
Ambala City.

No. 1881 Dated: 16/04/2024

Subject: Building safety certificate P K R Jain Sr. Sec. Public School for the Session 2024 - 25.

Reference: Your office Letter No. PKR (P) 27083 / 24 dated 16.04.2024.

The school building i.e. P.K.R. Jain Sr. Sec. Public School, Ambala City was visually inspected by the SDE P-7 alongwith JE incharge. The school building is inspected and visually it found safe for running classes. Hence, the school building safety certificate for year 2024 - 2025 may be issued with following conditions: -

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution authorities will be responsible for safety of building from every angle and Fire-Fighting equipment's should be in functional condition.
5. If the building of the school is to be extended, the same should be approved from reputed Structural Engineer.
6. Proof Checked structural drawings of the building should be sent to this office for record within 1 month from the issuing of NOC.
7. Institution shall also ensure safety precautions from false ceiling, vitrified used in dado.
8. NOC will be treated as cancelled by this office if the School violates any of the above points.

DA/NIL

Executive Engineer,  
Provincial Division No.1,  
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 7, PWD B&R Br; Ambala Cantt for information w.r.t. this office No.681 dated 07.05.2024.

DA/ NIL

Executive Engineer,  
Provincial Division No.1,  
PWD B&R Br; Ambala Cantt.